From: O"Connor, Kevin
To: Downtown West Project

Subject: public files

Date: Thursday, June 4, 2020 3:13:52 PM

Attachments: CSJ Interconnection Application Form Submitted to PG&E on 06-03-2020.pdf

Kevin O'Connor

Energy Resilience Coordinator

City of San Jose Community Energy Department

Email: kevin.oconnor@sanjoseca.gov

Ph: (408) 535-8538



INTERCONNECTION APPLICATION

Interconnection Applicant Information

Legal Name of Interco	onnection Applicant				
Name:	City of San J	ose, Calit	fornia		
	Kevin O'Connor				
Title:	Deputy Director, Community Energy Dept.				
Mailing Address:	200 E. Santa Clara St., Floor 14				
City:	San Jose	State:	CA	_ZIP: _	95112
	408-535-8538				
E-Mail Address:	kevin.oconnor@sanjoseca.gov				
Additional Contact In	formation				
Contact Name:	Lori Mitchell				
Director, Community Energy Dept.					
Mailing Address:	200 E. Santa Clara St., Floor 14				
City:	San Jose	State:	CA	ZIP:	95112
	408-535-4880				
E-Mail Address:	lori.mitchell@sanjoseca.gov				

INTERCONNECTION APPLICATION

Interconnection Facility Information

Describe the FERC tariffs under which service is being requested. Attachment 1 - Statement of Applicable Tariff & Eligibility
Describe Applicant's eligibility to apply for interconnection service under the tariffs identified.
Attachment 1 - Statement of Applicable Tariff & Eligibility
Specify proposed point of interconnection or site (with sufficient detail to locate point on a USGS map).
Attachment 2 - Vaults near PG&E's Station A on Otterson Street, San Jose, CA
Specify proposed voltage level of interconnection. 115kV
Specify requested type of interconnection (tap-line, double tap, loop). Double tap
If tap-line, does customer want to engineer, construct, and own?
San Jose proposes to engineer, construct, and own.
Description of type of load: summer or winter peaking, daily cycling, residential, commercial, (heavy, light) industrial, pump, dispatchable:
mixed use development, primarily commercial and industrial
Maximum load (MW) and power factor: MW @ p.f. Loads as shown in Attachment 3, PF as required by CAISO (Note: For loads connected to the CAISO Controlled Grid, power factor must remain between 0.97 and 0.99.)
Describe voltage regulation devices being installed to maintain CAISO required load power factor.
To Be Determined - will follow good utility practices.

Provide Load Forecast for 5-10 years (monthly energy and demand).
See Attachment 3 - Load Forecast
Proposed date for energizing the interconnection.
January 1, 2025
Requested term of Interconnection Service.
Long Term - 30+ years
Describe any on-site generation (where on-site generation exceeds 15% of site load, additional generator data will be required).
To Be Determined
Main transformer bank data, if applicable (MVA, voltages, impedance and connection). 115/12kV or 115/21 kV, Delta-Wye, 30/45 MVA
Provide general outdoor arrangement of the applicant's substation, if applicable. See Attachment 4 - General Arrangement
Provide applicant's substation one-line diagram, if applicable.
See Attachment 5 - Single Line Diagram
For pumping plants and industrial facilities, starting KVA and power factor of the larges motor or group of motors KVA PF To Be Determined
Describe Applicant's protection equipment.
Per PG&E's Transmission Interconnection Handbook

STATEMENT OF APPLICABLE TARIFF & ELIGIBILITY

This statement is not provided in the form of a legal opinion. San Jose is requesting service pursuant to the Pacific Gas & Electric Company Transmission Owner Tariff (TO Tariff) FERC Electric Tariff Volume No. 5 San Jose is an Eligible Customer as defined in PG&E TO Tariff Section 3.20 because it is a municipality and intends to be a utility that will own or control electric facilities to deliver energy between the point of interconnection and its retail customers and will generate, buy and/or sell energy into, out of, or through the California Independent System Operator Controlled Grid. San Jose is eligible for interconnection consistent with the provisions of Section 210(a) of the Federal Power Act.

LEGEND:

Blue - Existing Station A & OH 115kV Lines Orange - Proposed UG 115kV Lines requested by Google Green - Proposed Interconnection Facilities

requested by City of San Jose

ATTACHMENT 2 Green

POINT OF INTERCONNECTION






LOAD FORECAST

	Annual Peak	Annual Total Energy
Year	Load (MW)	(MWh)
2025	9.0	47,304
2026	25.2	132,451
2027	27.4	144,014
2028	27.4	144,014
2029	32.3	169,769
2030	39.7	208,663
2031	41.2	216,547
2032	44.3	232,841
2033	44.3	232,841
2034	47.9	251,762

NOTE: Annual Total Energy based on 60% Annual Load Factor.

NOTE: Monthly forecasts will be provided later.

GENERAL ARRANGEMENT ELECTRIC UTILITY BUILDING



SINGLE LINE DIAGRAM

