

From: [Barry Flynn](#)
To: [O'Connor, Kevin](#)
Cc: [Doug Boccignone](#); [Mike Keller](#)
Subject: Substation Building Floor Plan
Date: Friday, May 29, 2020 9:01:48 AM
Attachments: [AIS Floor Plan V2.pdf](#)

[External Email]

Hi Kevin:

Your note to Google on Wednesday included the statement:

- Please review and comment on Attachment 4 – General Arrangement

This is an approximate space plan for the Google substation that Arup mocked up some time ago. No comments on this. The GIS arrangement may not be necessary in a tapped arrangement. City to provide a diagram of general arrangement without specific detail.

Mike has taken another shot at the general arrangement that is attached. You may want to indicate to Google:

“We appreciate the comment that the GIS arrangement may not be necessary in a tapped arrangement. Please see the attached drawing that does not assume a GIS installation. Please let us know whether you think it should be sent to PG&E or you have any other suggestions. Your note indicates that the diagram is based upon the “Google substation that Arup mocked up some time ago”. Please indicate whether we should make other assumptions.

Barry Flynn

888-634-7516

This message is from outside the City email system. Do not open links or attachments from untrusted sources.

SUBSTATION BUILDING FLOOR PLAN

